WINSLOW TOWNSHIP FIRE PREVENTION DIVISION

EXIT SIGN & EMERGENCY LIGHTING TEST FORM

Repairs or maintenance should be reflected in the notes section of this form Person testing unit should indicate day of month and initials in the appropriate block. Monthly--ensure operation for 30 seconds, annually--test operation for minimum of 60 minutes.

#	LOCATION	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual 60 min. test

Notes: